

# SOLVES-IT! MULTI-COUNTER APPLICATION MODULE

Revision 1 for Software Version 1.0.0.0



PLC on a Chip Patent 7,299,099



*Smart Parts for Managing Automation*

9778 Mt. Gilead Rd.  
Fredericktown, OH 43019  
Toll Free: 1-800-245-2327  
Web: <http://www.divebiss.com>  
Email: [sales@divebiss.com](mailto:sales@divebiss.com)

# TABLE OF CONTENTS

<b>Table of Contents</b>	Page 1
Package Contents	Page 1
<b>Getting Started</b>	Page 2
How to Use this Manual	Page 2
<b>SI-APPMOD-MultiCount Basics</b>	Page 3
Get to Know the Module	Page 3
Module Mounting	Page 4
Module Input Power	Page 4
Module Operation	Page 5
User Interface	Page 5
Channel Reset Input Connections	Page 6
Output Connections	Page 6
Counter Pulse Input Connection	Page 7
Changing Channel Setpoints	Page 8
Expandability / Customization	Page 9
Programmed from Factory Specifications	Page 9

## WARNING!

The SI-APPMOD-MULTICOUNT, as with programmable controllers, must not be used alone in applications which would be hazardous to personnel in the event of failure of this device. Precautions must be taken by the user to provide mechanical and/or electrical safeguards external to this device. This device is **NOT APPROVED** for domestic or human medical use.

## PACKAGE CONTENTS

### Whats Included

Qty	Description	Part Number	Location
1	SI-200 with Software Pre-loaded	SI-200	In Box
1	Din-rail Socket	115-105328	In Box
4	Commutating Diodes	111-101012	In Box

# GETTING STARTED

This section explains how to read this manual and understand the symbols.

## HOW TO USE THIS MANUAL

In this manual, the following conventions are used to distinguish elements of text:

<b>BOLD</b>	Denotes labeling, commands, and literal portions of syntax that must appear exactly as shown.
<i>italic</i>	Used for variables and placeholders that represent the type of text to be entered by the user.
<b>SMALL CAPS</b>	Used to show key sequences or actual buttons, such as OK, where the user clicks the OK button.

In addition, the following symbols appear periodically in the left margin to call the readers attention to specific details in the text:



Warns the reader of a potential danger or hazard that is associated with certain actions.



Appears when the text contains a tip that is especially helpful.




Indicates that the text contains information to which the reader should pay particularly close attention.

**All Information and Specifications Subject to Change without Notice**

# MODULE BASICS

This section describes the SI-APPMOD-MultiCounter Application Module including input/output assignments and an operational description.

## GETTING TO KNOW THE MODULE



The module is connected to external devices via its included mounting socket.

### Connector Pin out

#### **Bottom View (Solves-It! Connector)**

- Pin 1 Channel 2 Output
- Pin 2 Channel 1 Output
- Pin 3 Counter Channel 1 Reset
- Pin 4 Counter Pulse Input (GPI1)
- Pin 5 Counter Channel 2 Reset
- Pin 6 Counter Channel 3 Reset
- Pin 7 Earth Gnd
- Pin 8 Input Power Common
- Pin 9 10-24.5VDC Input Power
- Pin 10 Output 3 - Not Used
- Pin 11 Channel 3 Output




Figure 2.1 - Module Pin-Out

**MODULE MOUNTING**

The Module mounts to an industry standard 11-pin Octal relay socket. To mount the module, align with the socket and firmly push into position.

**MODULE INPUT POWER**

! The module can be powered with 10-24.5VDC. The input power must be of sufficient supply to drive the module and the outputs (based on the load currents for each) Maximum current for the module is 150mADC and maximum load for each outputs is 300mADC. For the pre-programmed software, 3 outputs are used and may be on at a time. Exceeding a total output load of greater than 1ADC (more than 3 outputs at full load simultaneously) can damage the module. ⚡




Figure 2.2 - Module Input Power Diagram

## MODULE OPERATION

The SI-APPMOD-MultiCount module provides three counter channels that are pulsed by a common input. Each counter channel has an individual setpoint, output and reset.

For each channel, when the reset input is de-energized (false), the counter channel will increment by one for each pulse received on the Counter Pulse Input. When the reset is energized (true), the counter cannot count, will reset its count to zero and if the counter channel's output is energized, it will be de-energized. When the counter is equal to its setpoint, the channel's output is energized.

LED indicators I1-I3 indicate what channel data is displayed. I4 will flash with each pulse on the Counter Pulse Input. Please note, depending upon the frequency of the input, the LED may appear to be on-steady.

## USER INTERFACE

The user interface consists of two push-buttons; labeled B1 and B2, the Setpoint/Variable Display, four LED indicators (I1-I4) and the Status LED indicator.

### 1. Indicator 1

On-Steady indicates that current count of Channel 1 is displayed on the Setpoint / Variable Display. When flashing, the Channel 1 Setpoint is displayed.

### 2. Indicator 2

On-Steady indicates that current count of Channel 2 is displayed on the Setpoint / Variable Display. When flashing, the Channel 2 Setpoint is displayed.

### 3. Indicator 3

On-Steady indicates that current count of Channel 3 is displayed on the Setpoint / Variable Display. When flashing, the Channel 3 Setpoint is displayed.

### 4. Indicator 4

Pulses for each Counter Input Pulse that is detected.

### 5. Module Status Indicator

Flashing slowly indicates module problem  
Flashing quickly indicated module is operating

### 6. B1 Push-button

Each press will cycle one-step through the module setup menu. The menu # is displayed using the flashing I1-I4 indicators.

1. Channel 1 Setpoint
2. Channel 2 Setpoint
3. Channel 3 Setpoint

### 7. B2 Push-button

For each Setpoint displayed, pressing the B1 will increment the setpoint by one (1). Holding the B2 button will cause the setpoint to increase faster.

### 8. Setpoint / Variable Display

View the current counter values, configure the counter channel setpoints.




Figure 2.3 - User Interface

## CHANNEL RESET INPUT CONNECTIONS

The Channel Reset inputs for each channel are sourcing; therefore requiring a sinking device be connected. When the input is connected to common (shorted to common), the input is energized. Figure 2.4 provides a sample connection. As shown in Figure 2.4, switches are used to illustrate what is required; although, any device that operates the same may be used.




Figure 2.4 - Reset Input Connections

## OUTPUT CONNECTIONS

When outputs are energized, the output pin will be sourced with +V (equal to the module input power voltage). Each output can drive a load up to 500mA maximum (resistive). Depending upon the device connected to an output, a minimum load resistor may be required. If the output is energized at all times, connect a 470Ω to 1KΩ load from the output to common. Figure 2.5 is a typical output wiring diagram.




Figure 2.5 - Typical Output Connections

### COUNTER PULSE INPUT CONNECTION

The Counter Pulse Input is sourcing; therefore requiring a sinking device be connected. When the input is connected to common (shorted to common), the input is energized. Figure 2.4 provides a sample connection. The maximum frequency is 25Hz for the Counter Pulse Input.




Figure 2.6 - Pulse Input Connections

## CHANGING CHANNEL SETPOINTS



Indicators I1-I3 represent counter channels 1-3 respectively. If a channel indicator is on-steady, the actual counter value is displayed. If a channel indicator is flashing, the setpoint is displayed. Unless in the setup menu (indicator flashing), the display will cycle through all three current counter setpoints; displaying them (indicators will indicate which channels current count is displayed).

## CHANGING THE SETPOINT

1. Using the B1 button, cycle through the configuration menu until the desired channel's indicator is flashing.
2. Press the B2 button repeatedly to increment the setpoint time in 1 count increments. Pressing and holding the B2 button will cause the rate of the increment to increase. The count will increase to 9999 counts then reset and begin from zero.

To exit from the channel setpoint, press the B1 button until no indicators are flashing.

**EXPANDABILITY / CUSTOMIZATION**

As the module is based on the Solves-It!, Model SI-200, the program can be customized and its functionality expanded. Accessories are required. The program that was factory installed can be downloaded from <http://www.divelbiss.com>. The program can be edited to add additional functionality and logic. To gain functionality of some inputs and/or outputs, it may be necessary to re-assign the I/O that was factory configured. For more information about changing the functionality, download the Solves-It! User Manual and the EZ LADDER User Manual.

The following accessories are required to re-program the module and are included in the SI-APPMOD-PGMKIT:

- |              |                              |
|--------------|------------------------------|
| 1. SI-PGM    | Solves-It! Programming Cable |
| 2. EZLDCD-01 | EZ LADDER on CD.             |

**PROGRAMMED FROM FACTORY SPECIFICATIONS**

<b>Processor:</b>	Solves-It! Model 200, Based on PLC on a Chip™
<b>Memory:</b>	64K Flash
<b>Outputs:</b>	3 Sourcing SSR Outputs, rated 8-32VDC @ 400mADC Max. each. Output Voltage = Input Power Functionality: Channel 1-3 Output
<b>Power Requirements:</b>	8-32VDC @ 150mADC Max
<b>Indicators:</b>	11-14 LED Indicator, 1 Status LED Indicator
<b>Digital Inputs:</b>	3 Sourcing Inputs Channels 1-3 Reset
<b>Counter Input:</b>	1 Sourcing Input, 25Hz Maximum
<b>Display:</b>	4 Digit, 7 Segment Programmable LED Display
<b>Push Buttons:</b>	2 Programmable Push Buttons
<b>Operating Temp:</b>	-40-65° C
<b>Dimensions:</b>	3.62" Wide x 5.21" Length x 1.21" Tall.
<b>Mounting:</b>	Plugs into Industry standard 11-pin Octal Relay Socket
<b>Type:</b>	Plastic Housing

## Limited Warranty

Divelbiss Corporation warrants equipment will be free from defects in material and workmanship for a period of one (1) year from the date of the Divelbiss invoice that the equipment was furnished. Divelbiss Corporation will not be liable for any design furnished by Buyer and incorporated into the equipment.

In no event shall Divelbiss Corporation be liable for anticipated profits, consequential damages or loss of use of equipment or of any installation into which the equipment covered by this order may be put.

Divelbiss Corporation shall not be liable or responsible for any loss, injury, or damage resulting directly or indirectly from the use of software and/or programming in any way associated with the equipment of this order.

Obligations are to be limited to the repair or replacement at the Divelbiss Corporation plant, Fredericktown, Ohio, upon return of the part or component in question, prepaid by Buyer. The return freight charges to be paid by Divelbiss. The part or component is only to be returned to Divelbiss with a Returned Material Authorization number issued by the Divelbiss Service Department. Any warranty service (consisting of time, travel, and expenses related to such services) performed other than at Divelbiss Corporation plant, shall be at Buyer's expense.

Warranty of repaired or replacement products will be limited to ninety (90) days or the remainder of the original warranty whichever is greater.

Warranty is available only if Divelbiss Corporation is promptly notified in writing upon discovery of any alleged defect and examination of the subject product discloses, to Divelbiss satisfaction, that any defect has not been caused by misuse; neglect; improper installation; improper operation; improper maintenance, repair, or alteration; accidents; or unusual deterioration or degradation of the equipment or parts thereof due to physical environment or due to electrical or electromagnetic noise environment.

This warranty is in lieu of all other warranties, expressed, implied, or statutory, including warranties of merchantability or fitness for a specific purpose.